



Fire Extinguisher Use



Introduction

Fire extinguishers are designed to put out or control small fires. A small fire, if not checked immediately, will soon spread out of control. In fact, most big fires start out as small ones. It is important, therefore, that you equip your workplace with the proper fire extinguishers as part of your fire protection plan. It's also the law.

For a fire extinguisher to be effective, the following conditions must be met:

- ✚ the extinguisher must be right for the type of fire
- ✚ it must be located where it can be easily reached
- ✚ it must be in good working order
- ✚ the fire must be discovered while it is still small
- ✚ the person using the extinguisher must be trained to use it properly

This guideline discusses fire extinguishing methods, types of extinguishers and their proper selection, location, identification, maintenance and use. It also covers employee training and outlines the legal requirements for extinguishers in workplaces.

Fire Extinguishing Methods

Fires can be extinguished in one of four ways:

- ✚ **By cooling:** Water is used to cool the burning material below the temperature at which it starts to burn.
- ✚ **By smothering:** Carbon dioxide (CO₂) or foaming agents are used to smother the burning material so that air is excluded.
- ✚ **By removing the fuel:** This is usually very difficult to do. An example is turning off a fuel line.
- ✚ **By disrupting the chemical chain reaction or interrupting the flame:** Dry chemicals or halon are used to do this.

Types of Extinguishers

To help in choosing the proper extinguishers, fires are classed A, B, C, or D, according to the type of fuel (e.g., paper, grease, oil) that is involved in the fire. Extinguishers are available for use on one or more classes of fire, depending on the extinguishing agent they contain (e.g., water, chemicals). **Figure 1** below, will help you to match types of extinguishers to different classes of fire.

Some extinguishers are suitable for one class of fire only; others can fight two or even three classes of fire. However, no extinguisher will fight all four classes of fire. **Figure 2** gives examples of specific types of fire extinguishers, how they work, and the class(es) of fire on which they can be used.

Figure 1: Matching Classes of Fire and Types of Extinguishers

Fuel Source	Class of Fire	Type of Extinguisher (Extinguishing Agent)
Ordinary combustibles (e.g., trash, wood, paper, cloth)	A	Water; chemical foam; dry chemical*
Flammable liquids (e.g., oils, grease, tar, gasoline, paints, thinners)	B	Carbon dioxide (CO ₂); halon**; dry chemical; aqueous film forming foam (AFFF)
Electricity (e.g., live electrical equipment)	C	CO ₂ ; halon; dry chemical
Combustible metals (e.g., magnesium, titanium)	D	Dry powder (suitable for specific combustible metal involved)



Fire Extinguisher Use

* Dry chemicals, CO₂ and halon can be used on Class A fires, but may not be effective alone. They need supplementation with water.

** Halon extinguishers are no longer made, but some may still be in use. Dangerous gases are formed when halon is used to put out fires. Wear proper respiratory equipment, particularly in enclosed spaces. After use, do not allow anyone to enter the area until it has been well ventilated.

Selection

Using the wrong extinguisher to fight a fire can have serious results. For example, if a water-based extinguisher is used on a flammable liquid fire (**Class B** fire), the fire may flare up, spread, and cause personal injury to the user and others. If a water-based extinguisher is used to fight a fire in or near electrical equipment, the user could suffer an electric shock.

Follow these steps in selecting extinguishers for your workplace;

1. Conduct an assessment to identify your fire hazards and determine the type of extinguishers needed. The extinguishers you select must match the classes of fire most likely to occur. Remember to check your material safety data sheets to identify materials that could catch fire. The section on fire fighting measures gives information on the type of extinguishing agent needed to put out a fire involving the material. 
2. Determine the size of potential fires in each area and how fast they could spread. Extinguishers for **Class A** and **Class B** fires are rated for the size of fire they can handle. This rating appears on the label and is expressed as a number from 1 to 40 for **Class A** fires and 1 to 640 for **Class B** fires.

The higher the number, the larger the fire the extinguisher can put out, however, the higher the rating, the heavier the extinguisher. Extinguishers rated 2A:10BC are suitable for home or office fires.

Extinguishers for **Class C** fires depend upon such factors as the size of the electrical equipment, how it is constructed, whether it is enclosed, and the nature of other combustible materials in the area.

Agents for **Class D** fires should be carefully selected based on information in the material safety data sheet and the manufacturer's recommendations. The amount of agent needed depends on the surface area of the metal, and its shape and form.

Consult your local fire department to determine the number of fire extinguishers you need for your workplace.

Figure 2: Specific Types of Fire Extinguishers and their Uses

Water	Multi Purpose Dry Chemical	Chemical Foam	Compressed Gas
<ul style="list-style-type: none"> Pressurized, pump type Cools fire Use on Class A fires Do not use on electrical fires 	<ul style="list-style-type: none"> Stored pressure type Smothers fire with layer of powder Use on Class A, B and C fires 	<ul style="list-style-type: none"> Aqueous film forming foam (AFFF) type Smothers fire with foam Use on Class A and B fires 	<ul style="list-style-type: none"> Halon, CO₂ types Smothers fire with gas Use on Class B and C fires

3. Consider other factors that affect selection:
 - Possible health and safety hazards from chemical reactions between the extinguishing agent and the burning materials, or when using certain types of extinguishers in unventilated areas. Extinguishers with long-range



Fire Extinguisher Use

nozzles, for example, are available for use in confined spaces or other hazardous areas.

- ✚ Atmospheric conditions in areas where extinguishers are located. Extreme cold, for example, could make water-based extinguishers ineffective. Where there may be corrosive fumes, select fire extinguishers that can resist corrosion, or provide protection against corrosion.
- ✚ Physical abilities of the user. The size and weight of extinguishers should match the physical abilities of those who have to use them. Extinguishers shouldn't be too heavy for employees to handle.

4. Make sure that your extinguishers:
 - ✓ are approved by a recognized laboratory (replaced or new extinguishers must be approved by the Underwriters' Laboratories of Canada or
 - ✓ ULC, and labeled as such)
 - ✓ do not contain carbon tetrachloride, methyl bromide, or other toxic vaporizing liquids
5. Do a reassessment whenever you make changes in your workplace, e.g., when you change a work process or the materials you are using.

Location

No matter how carefully they are selected, fire extinguishers won't be of any use if they can't be reached in an emergency. Locate extinguishers where they can be readily reached for use while a fire is still small. However, don't locate them where they could be a hazard to employees, or where they could get damaged.



If not equipped with wheels, ensure that portable extinguishers weighing more than 18 kilograms (kg) or 39 pounds (lbs.) are installed so that the top is not more than 1.1 meters (m) or 3.6 feet (ft.) above the floor. Those weighing 18 kg or less must not be more than 1.5m (5 ft.) above the floor.

Here are some general pointers for where to locate extinguishers in your workplace. Locate them so that they are visible, along with their operating instructions and identification marks and where they can be easily reached (i.e., they must not be blocked by machines or materials);

- ✚ in or near corridors or aisles leading to exits however, they must not block aisles
- ✚ close to potential fire hazards, but not so close that they could be damaged or cut off by a fire
- ✚ where they will not expose people using them to undue risk, e.g., using a halon extinguisher in an unventilated area
- ✚ where they will not be damaged by moving trucks, cranes or other work activities, or corroded by chemical processes
- ✚ so that they are protected against the elements (if stored outdoors)

In special areas

Where highly combustible material is stored in small rooms or enclosed spaces: locate the extinguisher outside of the room (this will force the potential user to exit the room and then decide whether to re-enter it to fight the fire).

For service rooms that contain electrical equipment: locate extinguishers in or near the room.

On vehicles or in areas where extinguishers are subject to jarring or vibration: mount extinguishers on brackets designed to



Fire Extinguisher Use

withstand vibration.



Post signs to show the locations of fire extinguishers, particularly in large floor areas where they could be easily blocked from view. The signs should be large enough to be seen clearly from a distance. Mount the extinguisher so that it will not be knocked over or damaged. Make sure that access to the extinguisher is not blocked.



Identification

Manufacturers place markings on extinguishers to indicate the class or classes of fire for which they are suitable. To make identification easier in an emergency, consider applying class ratings to wall panels near extinguishers. These markings should be easy to see from a distance of 4.5m (15 ft.).

One marking system uses letters, symbols and colors (see below).

Another marking system uses pictures which show both the uses and non-uses of the extinguisher. Pictures give more information, but employees will need training to recognize and understand them. Note that with both marking systems, the use of color is optional.

Symbol and Color Markings on Extinguishers

Symbol	Description	Symbol	Description
<p>Ordinary</p>  <p>Combustibles</p>	Extinguishers for Class A fires are identified by a triangle containing the letter "A". If colored, the triangle is green.	<p>Flammable</p>  <p>Liquids</p>	Extinguishers for Class B fires are identified by a square containing the letter "B". If colored, the square is red.
<p>Electrical</p>  <p>Equipment</p>	Extinguishers for Class C fires are identified by a circle containing the letter "C". If colored, the circle is blue.	<p>Combustible</p>  <p>Metals</p>	Extinguishers for Class D fires are identified by a star containing the letter "D". If colored, the star is yellow.

Markings Showing Uses and Non-Uses of Extinguishers

Note regarding colors (if used):

- A blue background indicates uses.
- A black background with a bright red slash indicates non-uses.

Class A Fires



Class A, B Fires




Class B, C Fires

Class A, B, C Fires



Fire Extinguisher Use



Maintenance

Extinguishers must be properly maintained to ensure that they will work when needed, and that they are safe to use. A carbon dioxide extinguisher, for example, can build up a high static charge if it is used when there is a breakdown of the insulation around the discharge horn. This can cause electric shock. Adequate maintenance of extinguishers consists of regular inspections, recharging as needed, and a complete annual checkup and servicing. Records must be kept of all maintenance work carried out, including inspections. Testing and servicing is usually carried out by a service agency. If employees in your company look after testing and servicing, they must be trained and fully qualified to do so.

Recharging / Servicing

Recharge spent extinguishers immediately and return them to their locations. Follow manufacturer's instructions for recharging. Completely examine each extinguisher at least once a year, and whenever your monthly inspections indicate that this may be needed. Replace defective parts and extinguishers, recharge extinguishers as needed, and ensure that hydrostatic tests are carried out according to the manufacturer's instructions. Extinguishers that contain Halon 1211 or 1301 must be serviced according to the requirements of **Environmental Protection Act - O. Reg. 413/94**. Set up a maintenance schedule for extinguishers so that they are not all out of service at the same time.



Inspections

Fire extinguishers must be inspected at least once a month and more often where needed. Inspections are visual checks to determine that

The extinguisher is well supported

- ✓ Hangers are fastened solidly
- ✓ It is accessible
- ✓ can be easily reached
- ✓ location signs are clear
- ✓ class markings are clear
- ✓ Operating instructions are clear

It is in working condition

- ✓ discharge opening is clear
- ✓ is fully charged
- ✓ has not been tampered with
- ✓ is not damaged
- ✓ hydrostatic testing has been done
- ✓ The ring pin is in place and the seal is intact

Record Keeping

Attach a durable tag to each extinguisher that shows:

- ✓ dates of monthly inspections, recharging, and servicing
- ✓ name of servicing agency
- ✓ signature of person who performed the service





Fire Extinguisher Use

Maintain a permanent record for each fire extinguisher that shows:

- ✓ serial number and type of extinguisher
- ✓ location of extinguisher
- ✓ inspection date
- ✓ description of maintenance work or hydrostatic tests carried out
- ✓ date of next inspection
- ✓ date of scheduled annual servicing
- ✓ inspector's comments
- ✓ inspector's signature

Extinguisher Use

As soon as a fire is discovered:

- ✓ Sound the alarm and start to evacuate
- ✓ Call the fire department

These are important steps for everyone's safety, even if you feel the fire can be brought under control by using an extinguisher.

Tips for safe extinguisher use:

Test that the extinguisher works before you approach the fire.

Protect yourself at all times.


Take care, speed is essential but it is more important to be cautious.

Keep your back to the exit at all times and stand 2 to 2.4m (6 to 8 ft.) away from the fire.

Follow the 4-step P-A-S-S procedure.

1. **P**ull the pin (release the lock latch or press the punch lever).
2. **A**im the nozzle at the base of the fire.
3. **S**queeze or press the trigger.
4. **S**weep the extinguisher from side to side.

To operate an extinguisher:



If the fire does not go out immediately or the extinguisher appears to be getting empty, leave the area at once. Back out with the lever squeezed and the nozzle pointed at your feet. This will help protect you until you are out of the area.

Employee Training

All employees who may be required to use fire extinguishers should receive training. Training should cover:

- ✓ extinguisher locations
- ✓ classes of fire most likely to break out in your workplace and the proper extinguishers to use
- ✓ markings on extinguishers
- ✓ when and how to use extinguishers
- ✓ importance of sounding the alarm
- ✓ health and safety hazards
- ✓ personal protective equipment



Use lectures and demonstrations, and give employees plenty of opportunity to practice using extinguishers. Consider having them practice on extinguishers that need recharging. With increased confidence, employees are more likely to respond effectively to fire emergencies. Make sure employees are aware of the operating instructions posted by extinguishers. Provide retraining as needed.



Fire Extinguisher Use

What the Law Says

Occupational Health and Safety Act

29 CFR 1910 Section 157 of the OSHA Standards for General Industry specifies the requirements for portable fire extinguishers in the workplace.

29 CFR 1910 Section 37 of the OSHA Standards for General Industry specifies the requirements for means of egress.

29 CFR 1910 Section 38 of the OSHA Standards for General Industry specifies the requirements for employee emergency plans & fire prevention plans.

Resources

For more information, consult the following:

National Fire Protection Association (NFPA) / Fire Protection Handbook

Suppliers' material safety data sheets for the hazardous materials used in your workplace

AFI91-203 15 JUNE 2012

Chapter 6

FIRE PROTECTION AND PREVENTION

6.1. Hazards.

6.1.1. General. The maintenance and operation of portable fire extinguishers and fire suppression systems may involve exposure to toxic fire extinguishing agents and by-products of combustion. Breathing toxic gases, absorption through skin contact or ingestion of toxic liquids is hazardous to your health. The severity of the hazard depends upon the type of chemical, concentration and duration of exposure. Additionally, fires produce toxic by-products of combustion, consume oxygen and produce high temperatures which create areas immediately dangerous to life and health (IDLH). It is important personnel receive training in the proper use of available portable fire extinguishers and fixed fire suppression systems, and fire education safety on preventing fires, protecting themselves and intervening early when fire occurs.